

# LPCB

## This is to Certify

**AMPAC Technologies Pty Ltd**  
7 Ledger Road, Balcatta, Western Australia, 6021

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

**55000-122AMP, 55000-127AMP,  
55000-132AMP & 5500-137AMP**  
Heat Detectors

which have complied with the requirements of the following:

**EN54-5: 2000 + A1: 2002**


**Certificate No: 010p-(cl-2)**

**Issue Number: 01**

**Date of Issue: 23 August 2012**

**Signed for and on behalf of LPCB**

**M McCULLAGH**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us.

# LPCB

## Appendix to Certificate

Certificate No: 010p-(cl-2)

**AMPAC Technologies Pty Ltd**

Certified Products	LPCB Ref. No.
55000-122AMP Series 65 Conventional Class A1R heat detector - Standard (45681-200AMP mounting base) <sup>1</sup> <i>Meets the requirements of EN54: Part 5 - Class A1R</i>	010p/06
55000-127AMP Series 65 Conventional Class BR heat detector - Standard (45681-200AMP mounting base) <sup>1</sup> <i>Meets the requirements of EN54: Part 5 - Class BR</i>	010p/09
55000-132AMP Series 65 Conventional Class CR heat detector - Standard (45681-200AMP mounting base) <sup>1</sup> <i>Meets the requirements of EN54: Part 5 - Class CR</i>	010p/12
55000-137AMP Series 65 Conventional Class CS heat detector - Standard (45681-200AMP mounting base) <sup>1</sup> <i>Meets the requirements of EN54: Part 5 - Class CS</i>	010p/15

### Bases:

45681-200AMP Series 60/65 mounting base  
45681-201AMP Series 60/65 diode mounting base  
45681-245AMP Series 65 relay mounting base  
45681-246AMP Series 65 auxiliary relay mounting base  
45681-247AMP Series 65 EOL 12 Volt mounting base  
45681-248AMP Series 65 EOL 24 Volt mounting base

### Notes:


<sup>1</sup> Also certified for use with 45681-245AMP, 45681-246AMP, 45681-247AMP, 45681-248AMP and 45681-201AMP mounting bases.

**Appendix Issue No: 01**

**Page: 2 of 2**

**Date of Issue: 23 August 2012**

**Signed for and on behalf of LPCB**



**M McCULLAGH**



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: [www.redbooklive.com](http://www.redbooklive.com)  
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit [www.redbooklive.com](http://www.redbooklive.com) or contact us