

Certificate of constancy of performance,

0832-CPR-F1495

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

58000-005AMP Discovery Type B Intelligent Open Area Sound Beacon (Red)
(For full product details and conditions of use refer to appendix)

Produced by or for

AMPAC Technologies PTY Ltd

7 Ledger Road
Balcatta
6021
Australia

and produced in the manufacturing plant(s)

Apollo Fire Detectors Limited

36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 23 May 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 23 May 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1495

Bases:

45681-517AMP Enhanced deep isolating base (White)
45681-518AMP Enhanced deep isolating base (Red)

Notes:

1. Meets the requirements of EN 54-3:2001 at the following tones:
T1- Apollo Evacuation 558Hz,0.5s/840Hz,0.5s
T3- Dutch Slow Whoop 500-1200Hz in 3.5s, 0.5s off
T4- German DIN1200-500Hz over 1s
2. The Beacon function is not approved to EN 54-23

Variants:

58000-007AMP (White)



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 23 May 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.