

To whom it may concern,

EMS has conducted compatibility testing between the following Ampac Loopsense fire panel and EMS FireCell wireless fire detection products.

Ampac Loopsense Fire Alarm Panel:

Ampac Loopsense Panel - Software Version v1.06.05.EN54
Loopmaster Configuration Software - Software Version 1.02.2.1

EMS FireCell Product Range:

FCX-500-004-V3 Radio Hub 4 Loop - Software Version V3.15
FCX-500-444-V3 Radio Hub 4 Loop - Software Version V3.15
FCX-532-001 Fusion Radio Loop Module - Software Version V3.04
FC-555-001-V3 Radio Cluster Communicator - Software Version V3.16
FC-555-331-V3 Radio Cluster Communicator - Software Version V3.16
FC-555-024-V3 Radio Cluster Communicator - Software Version V3.16
FCX-170-001 Wireless XP Detector Base
FCX-191-000 Wireless XP Combined Sounder / Detector Base
FCX-191-200 Wireless XP Combined Sounder / Detector and Visual Indicator Base
FCX-178-001 Wireless Remote Indicator Module
FC-200-002 Wireless Call Point
FC-171-001 Wireless Sounder Base Red / White (FC-171-002)
FC-610-001 Wireless Dual I/O Unit

Signed - on behalf of EMS



Daniel King

R&D Director

The information contained within this literature is correct at time of publishing. Future hardware and software updates to the aforementioned Control Panel models may cause unforeseen changes to system operation. The EMS Security Group Ltd reserves the right to change any information regarding products as part of its continual development enhancing new technology and reliability. The EMS Security Group advises that any product literature issue numbers are checked with its head office prior to any formal specification being written.