

Fire detection and evacuation solutions that save lives.

WIP Remote Buzzer Plate

Features

- Piezoelectric plate mounted buzzer
- 84dB @ 1M SPL output
- Easy to read “WARDEN INTERCOM POINT” text
- Connects to Ampac 2 wire & 3 wire WIP phones
- Ensures compliance to AS1670.4 requirements

Description

The remote warden intercom buzzer plate allows a Ampac warden intercom phone to be mounted inside of a enclosure, cupboard or fire and security cabinet while still maintaining the required 80dB(A) @ 1m requirements as stated in AS1670.4 2015 & 2018.

The remote intercom buzzer can be mounted outside a cabinet or cupboard to provide building wardens ample notification of an incoming call with the WIP enclosure closed.

The Ampac warden intercom phone buzzer plate mounts with ease to a single gang mounting box (not supplied). A double sided terminal block connection is provided to connect the remote buzzer plate directly into the remote buzzer output on the Ampac range of warden intercom phones.



WIP Remote Buzzer Plate—209-0028

Item Numbers

209-0028 WIP Remote Buzzer Plate

Specifications

Quiescent Current	NA
Alarm Current	20mA @ 24V
Monitoring	NA
Mounting	Single Gang Backbox
Temperature	-20°C to 70°C
Humidity	0-95% non-condensing
Wiring	2 core

For more detailed installation instructions please see MAN1813-8 EV3000 Install and Commissioning Manual -2wire

