



# Certificate of Conformity

| Certificate num.  | Registration date | Version     | Valid until               |             |
|-------------------|-------------------|-------------|---------------------------|-------------|
| <b>afp - 3686</b> | 29-Apr-2022       | Number<br>4 | Issue date<br>13-Mar-2025 | 30-Apr-2026 |

Page 1 of 3

## Product designation

**Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Altronic Distributors Pty Ltd  
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

## Registrant

Altronic Distributors Pty Ltd  
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

### Producer

Altronic Distributors Pty Ltd  
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

## Conformance criteria and evaluation

The Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS ISO 7240.24:2018, 'Fire detection and alarm systems - Part 24: Fire alarm loudspeakers'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

|                   |                   |             |                           |             |
|-------------------|-------------------|-------------|---------------------------|-------------|
| Certificate num.  | Registration date | Version     | Valid until               |             |
| <b>afp - 3686</b> | 29-Apr-2022       | Number<br>4 | Issue date<br>13-Mar-2025 | 30-Apr-2026 |

Page 2 of 3

## Producer's description

The Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker is intended to provide emergency warning audible broadcasts either for indoor applications.

The equipment is fitted with a 100 mm diameter paper cone speaker driver, and is rated for a maximum power output of 5 W when provided with an input signal of 100 Vac. Five taps are provided on the included transformer for operating at a range of output levels.

The Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker includes a white perforated plastic circular front grill, approximately 205 mm in diameter, with a concentric pattern of holes, fitted to a cylindrical housing of diameter 280 mm and height of 80 mm. It is fitted with six retaining clips..

The Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker is intended for indoor applications.

## Technical specification

The following details are a representative extract of the technical specification for the Redback, Model CF0705/0706, type A, indoor, surface mount, emergency sound-system loudspeaker and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

| Variant |        | Description   | Housing and grille colour |
|---------|--------|---|---------------------------|
| Type    | Ident. |   |                           |
| Model   | CF0705 | Type A, indoor, surface mount, emergency sound-system loudspeaker | White                     |
|         | CF0706 |   | Black                     |

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

|                                    |   |
|------------------------------------|---|
| Rated noise power                  | 5 Watts (100V line)   |
| Power taps & impedance (100V line) | 0.33W (30k $\Omega$ ), 0.66W (15k $\Omega$ ), 1.25W (8k $\Omega$ ), 2.5W (4k $\Omega$ ), 5W (2k $\Omega$ )  |
| Sensitivity                        | 91dB (1W @ 1m), 79dB (1W @ 4m)  |
| Maximum sound pressure level       | 97dB (5W @ 1m), 85dB (5W @ 4m)  |
| Frequency response                 | 100Hz - 15kHz   |
| Coverage angle (-6dB)              | 500Hz: >180°, 1000Hz: 155°, 2000Hz: 120°, 4000Hz 80°  |
| Environmental                      | Type A (for indoor applications as per standard)  |
| Speaker component                  | 100 mm (4") paper cone speaker  |
| Mounting method                    | Surface attachment  |
| Line monitoring                    | Yes, 22 $\mu$ F bipolar capacitor   |
| Applicable cable                   | 2.5 mm <sup>2</sup> (14AWG) max conductor area  |
| Connection                         | 4 way screw terminal  |
| Finish                             | White (CF0705) flame retardant ABS grille and housing or black (CF0706) grille and housing (Taitalac 8540T)<br>Clear Flame retardant ABS spring clips (Makrolon 6557) |
| IP rating                          | IP 21C  |
| Dimensions                         | 280 $\varnothing$ x 80 mm   |
| Weight                             | 0.9 kg  |

# Schedule to Certificate of Conformity

|                   |                   |             |                           |             |
|-------------------|-------------------|-------------|---------------------------|-------------|
| Certificate num.  | Registration date | Version     | Valid until               |             |
| <b>afp - 3686</b> | 29-Apr-2022       | Number<br>4 | Issue date<br>13-Mar-2025 | 30-Apr-2026 |

Page 3 of 3

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference   |                | Title / description  | Date issued<br>(or date validated) | Source                                   |
|-------------|----------------|--|------------------------------------|--|
| Ident. type | Ident.         |  |                                    |  |
| Report      | XF2980/R4      | Evaluation for Conformity of the Redback, Model CF0705/6, 5 W, Type A, indoor, surface mount, emergency sound-system loudspeaker to the requirements of AS ISO 7240.24:2018  | 23-Mar-2022                        | CSIRO, Fire Systems Laboratory, AU       |
| Datasheet   | CF705<br>CF706 | Redback Data Sheet<br>CF0705 100mm (4") 100V 5W Surface Mount Speaker White<br>AS ISO7240.24:2018<br>CF0706 100mm (4") 100V 5W Surface Mount Speaker Black AS<br>ISO7240.24:2018<br>(CF0705-6 Datasheet FINAL Rec JW 18-1.pdf) | 18-Jan-2022                        | Altronic Distributors Pty Ltd,<br>WA, AU |