

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0324

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### 13U EvacU Elite, Wall Mounted Voice Alarm Control and Indicating Equipment (VACIE)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Ampac Pty Ltd,  
7 Ledger Road,  
Balcatta,  
6021,  
Western Australia

Ampac Pty Ltd,  
7 Ledger Road,  
Balcatta,  
6021,  
Western Australia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment EN 54-16:2008 - Voice alarm control and indicating equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 14 April 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



Eman Mattie Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 14 April 2022

Issue Date: 14 April 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## BRE Global

## UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

### APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0324

#### 13U EvacU Elite, Wall Mounted Voice Alarm Control and Indicating Equipment (VACIE)

##### Wall Mounted VACIE

Incorporating the following mandatory modules:

BRD63PDB1-A Power Distribution Board  
BRD63ABB1-A Amplifier Backplane Board  
BRD63CPU1-A Distribution CPU  
BRD63GUI1-A Graphical User Interface Primary

ASS63CPU-NET EvacU Elite CPU Network incorporating:

BRD63NIC1-A Network Interface Card

ASS63PSU12M Primary Power Supply incorporating

BRD63PCC1-A Power Control Card - Primary  
RCB-1600-24 Meanwell Power Supply

##### Network SFP Modules

OEM3087 IC SFP VDSL Transceiver Module SFP-V5311-L-O "COPPER"  
OEM3088 IC SFP VDSL Transceiver Module SFP-V5311-L-R "COPPER"

Incorporating the following optional modules:

BRD63ILC1-A Quad Radial Line Card  
BRD63LILC-A Dual Loop Line Card  
BRD63LPA1-A Dual 25W Amplifier  
BRD63LPA1-B 50W Amplifier  
BRD63MIC1-A Multi-Purpose Interface Card  
BRD63MOC1-A Multi-Purpose Output Card  
BRD63GUI1-B Graphical User Interface Secondary

ASS63PSU12S Secondary Power Supply incorporating

BRD63PCC1-B Power Control Card - Secondary  
RCB-1600-24 Meanwell Power Supply

Certified with the following options with requirements from EN 54-16:

Eman Mattie Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 14 April 2022

Issue Date: 14 April 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global****UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0324****13U EvacU Elite, Wall Mounted Voice Alarm Control and Indicating Equipment (VACIE)**

7.3	Audible warning
7.4	Delays to entering the voice alarm condition
7.5	Phased evacuation
7.6.2	Manual silencing of the voice alarm condition
7.7.2	Manual reset of the voice alarm condition
7.8	Output to fire alarm devices
7.9	Voice alarm condition output
8.3	Indication of faults related to the transmission path to the CIE
8.4	Indication of faults related to voice alarm zones
10	Disabled condition
10	Voice alarm manual control
12	Emergency microphone(s)

## Notes:

1. The ASS63WIPM Primary warden intercom phone, ASS63WIPS Radial WIP Handset and ASS63LWIP Loop WIP Handset were connected to the VACIE as ancillary equipment to verify the functionality only.
2. The OEM3095 EVACU Elite SFP Single Mode Single Fibre Side A (SFP-GE-BX, BIDI, 1000Base, 1310TX/1490nmRX, SMF, 10km, LC simplex, DOM) and OEM3096 EVACU Elite SFP Single Mode Single Fibre Side B (SFP-GE-BX, BIDI, 1000Base, 1490TX/1310nmRX, SMF, 10km, LC simplex, DOM) were functionally tested but were not subjected to the environmental and EMC tests.



Eman Mattie Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 14 April 2022

Issue Date: 14 April 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)