

Certificate of Product Approval

Certificate Number: 010p-(cl-2)

Issue: 05

Ampac Pty Ltd

7 Ledger Road
Balcatta
6021
Western Australia

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors

58000-400AMP
55000-122AMP
55000-127AMP
55000-132AMP
55000-137AMP
55000-420AMP

(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

1 July 2022

Date of Issue

23 August 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 010p-(cl-2)

Issue: 05

Ampac Pty Ltd

Certified Product	Description	LPCB Ref.No.
58000-400AMP	Discovery Analogue Addressable Category P Heat Detector (45681-209AMP and 45681-210AMP bases) Notes: 1. Meets the requirements of EN54: Part 5 at the following modes: - Category A1R in mode 1 and in conventional mode - Category A2 in mode 2 and in conventional mode - Category A2S in mode 3 and in conventional mode - Category CR in mode 4 and in conventional mode - Category CS in mode 5 and in conventional mode 2. Certified with Apollo Discovery, XP95, and S90 digital communications protocols configured for the Discovery Heat Detector in accordance with manufacturer's instructions.	010p/03
55000-122AMP	Series 65 Conventional Category A1R Heat Detector (45681-200AMP base) Notes: 1. Meets the requirements of EN54: Part 5 at Category A1R 2. Also certified for use with 45681-245AMP, 45681-246AMP, 45681-247AMP, 45681-248AMP and 45681-201AMP mounting bases.	010p/06
55000-127AMP	Series 65 Conventional Category BR Heat Detector (45681-200AMP base) Notes: 1. Meets the requirements of EN54: Part 5 at Category BR 2. Also certified for use with 45681-245AMP, 45681-246AMP, 45681-247AMP, 45681-248AMP and 45681-201AMP mounting bases.	010p/09
55000-132AMP	Series 65 Conventional Category CR Heat Detector (45681-200AMP base) Notes: 1. Meets the requirements of EN54: Part 5 at Category CR 2. Also certified for use with 45681-245AMP, 45681-246AMP, 45681-247AMP, 45681-248AMP and 45681-201AMP mounting bases.	010p/12
55000-137AMP	Series 65 Conventional Category CS Heat Detector (45681-200AMP base) Notes:	010p/15

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan

Verifier

1 July 2022

Date of Issue

23 August 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 010p-(cl-2)

Issue: 05

Ampac Pty Ltd

Certified Product	Description	LPCB Ref.No.
	<ol style="list-style-type: none"> Meets the requirements of EN54: Part 5 at Category CS Also certified for use with 45681-245AMP, 45681-246AMP, 45681-247AMP, 45681-248AMP and 45681-201AMP mounting bases. 	
55000-420AMP	XP95 Analogue Addressable Category A2S Heat Detector (45681-209AMP and 45681-210AMP bases) Notes: <ol style="list-style-type: none"> Meets the requirements of EN54: Part 5 at Category A2S Certified with Apollo Discovery, XP95, and S90 digital communications protocols configured for the Discovery Heat Detector in accordance with manufacturer's instructions. 	010p/22

Bases

45681-200AMP Series 60/65 mounting base
 45681-201AMP Series 60/65 diode mounting base
 45681-245AMP Series 65 relay mounting base
 45681-246AMP Series 65 auxiliary relay mounting base
 45681-247AMP Series 65 EOL 12 Volt mounting base
 45681-248AMP Series 65 EOL 24 Volt mounting base
 45681-209AMP XP95/Discovery standard deep mounting base
 45681-210AMP XP95 mounting base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan

Verifier

1 July 2022

Date of Issue

23 August 2012

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre